



## **NBR COOLBOX 20 - Stock Ref:- 412258**

### **Installation Guidance Sheet**

A non-mechanical back-draught shutter is included within the kit but extreme winds can result in the shutters opening and closing.

Consideration must be given to protect the external termination or the position of this termination to prevent this occurrence as referenced within Part F 2021 - Control of ventilation intakes. This would involve installation of the external termination (supplied by others) away from prevailing winds.

Alternatively Mechanical back-draught shutters can be sourced on the open market, when particularly challenging environmental conditions development. Please see the Options below:

Option 1 – Relocate the external termination away from prevailing winds.

Option 2 – Mechanical back-draught shutters can be sourced on the open market.

Option 3 – The back-draught shutter could be excluded from the installation but a draught would be very apparent in the winter months hence We do not recommend this option 3.

