



Installation instructions

Surge Protection Device (Single Module)



THIS DEVICE IS NOT SUITABLE FOR DUAL RCD UNITS (For options contact Wylex Technical)

IMPORTANT INFORMATION

This unit should be installed by a qualified competent person in accordance with all relevant legislation and regulations including building regulations and wiring regulations BS 7671. If in doubt contact a qualified competent person.

- Turn off all power supplying this equipment before working on or inside the equipment.
- Always use a properly rated volt-sensing device to confirm the power is off.
- Replace all devices, doors and covers before turning on the power to this equipment.


Failure to follow these instructions could result in serious injury or death.

DO NOT USE POWER TOOL SCREWDRIVERS ON ELECTRICAL CONNECTIONS

1. Technical Information


BSI Standard	BSEN61643-11
Type Test Class	Type 2
Uc – Max. continuous operating voltage	275 VAC
Up – Voltage protection level (L-N), (N-PE)	1.3 kV
In – Nominal discharge current for class II	20 kA
I _{max} – Maximum discharge current	40 kA
I _{sc} – Short circuit current rating	25 kA
Degree of protection	IP20

2. Circuit Diagram for connection within a consumer unit (High Integrity)



Note: Only Main Switch, High Integrity & Split Load units are compatible with this SPD kit. Dual RCD are not compatible but bespoke kits are available, contact Wylex Technical for further details

3. SPD Cable connection sizes



Terminal	Min. Cable Size	Max. Cable size
Live	Ø 2.5 mm sq*	Ø 25 mm sq
Neutral / Earth	Ø 2.5 mm sq*	Ø 10 mm sq
RSC	Ø 0.14 mm sq	Ø 1.5 mm sq

* As per BS7671 the minimum sized cable for a Type 2 SPD is Ø 6mm sq. Neutral & Earth cables are supplied with this SPD. Use the crimp supplied on final termination of the prepared Earth cable.


4. Tightening Torque Values

Terminal	Tightening Torque
Live	2 Nm
Neutral / Earth	1.2 Nm
RSC	0.25 Nm

Use No.2 Pozidriv Screwdriver (PZ2) for all terminals


It is good practice to check the tightness torque of all connections prior to re-fitting the enclosure or consumer unit cover

5. SPD Wiring



$a + b \leq 0.5 \text{ m}$ Recommended
 $\leq 1 \text{ m}$ Maximum

6. Remote Signaling Contact (RSC)



U _{max} / I _{max} a.c.	250 V / 0.5 A
U _{max} / I _{max} d.c.	30 V / 1.5 A




Installation instructions

Surge Protection Device (Single Module)




7. Connection to Fixed Pin Type Busbar




With the terminal cage of the SPD wound fully out, slide onto the busbar adjacent to the Switch (Way 1.) Fully screw down the Live terminal using the appropriate tightening torque.

8. Connection to Flexible Comb Busbar



With the terminal cage of the SPD wound fully out, clip onto the DIN rail adjacent to the Switch (Way 1.) If the busbar is already fitted it may need to be removed and re-fitted. Fully screw down the Live terminal using the appropriate tightening torque.

9. Connection to a Balcony Busbar




With the terminal cage of the SPD wound fully out, slide onto the busbar adjacent to the Switch (Way 1), ensuring that the busbar is underneath the screw head. Fully screw down the Live terminal using the appropriate tightening torque.

10. Reposition Consumer Unit Cover

Add circuit ways over-label (as supplied) and Icons where applicable. For other replacement parts e.g. Busbars contact Wylex technical.

11. Cartridge Indication




A full green window indicates a cartridge in good working order. Any red indication in the window means the cartridge is no longer working and must be replaced at the earliest opportunity.


12. Replacement Cartridge

The cartridge is fitted with internal overload protection and can take numerous surges before it will need to be replaced. For replacements contact your local wholesaler quoting the part number NMT2SPD/P

13. Cartridge Removal and Re-fitting



Remove the enclosure or consumer unit lid, slide the cartridge upwards from the base. Discard used cartridge in accordance with WEEE regulations.



When fitting a new Cartridge care should be taken to align the two pips with the indents in the base module. The cartridge will only fit one way and should not be forced incorrectly. Ensure cartridge is inserted with no gaps to the base of the SPD.

14. Insulation resistance measurement

Unplug the cartridge before performing an insulation resistance measurement in the system, otherwise inaccurate measurements are possible. Re-fit cartridge as 13 above after the insulation resistance measurement.



Electrium Sales Limited, Walkmill Lane, Cannock, WS11 0XE
Tel: 01543 455000 Fax: 01543 455001



Waste electrical products should not be disposed of with household waste. Please recycle where waste disposal facilities exist. Check with your retailer, wholesaler or local authority for recycling advice.

